Data sheet

SIPLUS NET CSM 1277 with conformal coating based on 6GK7277-1AA10-0AA0 . Compact Switch Module CSM 1277 Connection SIMATIC S7-1200 and up to 3 further nodes to Industrial Ethernet with 10/100 Mbit/s



Figure similar

Product type designation	CSM 1277
Transmission rate	
Transfer rate	10 Mbit/s, 100 Mbit/s
Supply voltage, current consumption, power loss	
Product component / fusing at power supply input	Yes
Fuse protection type / at input for supply voltage	0.5 A / 60 V
Consumed current / maximum	0.07 A
Permitted ambient conditions	
Ambient temperature	
 during operation 	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
Relative humidity	
with condensation / maximum	100 %; r.F., incl. condensation/frost permitted (no commissioning in bedewed state)

Ambient condition / relating to ambient temperature -	0 +60 °C at 1080 hPa 795 hPa (-1000 m +2000 m) // 0
air pressure - installation altitude	+50 °C at 795 hPa 658 hPa (+2000 m +3500 m) // 0 +40 °C at 658 hPa 540 hPa (+3500 m +5000 m)
Resistance to biologically active substances /	Yes; Compliance with EN 60721-3-3, Class 3B2 mold, fungus,
conformity acc. to EN 60721-3-3	and sponge spores (except fauna). The supplied plug covers must
•	remain in place over the unused interfaces during operation!
Resistance to chemically active substances /	Yes; Compliance with EN 60721-3-3, class 3C4 incl. salt spray
conformity acc. to EN 60721-3-3	according to EN 60068-2-52 (severity 3). The supplied plug
	covers must remain in place over the unused interfaces during
	operation!
Resistance to mechanically active substances /	Yes; Compliance with EN 60721-3-3, Class 3S4 including sand,
conformity acc. to EN 60721-3-3	dust. The supplied plug covers must remain in place over the
Protection class IP	unused interfaces during operation! IP20
Protection class IP	IP20
Design, dimensions and weight	
Width	75 mm
Height	100 mm
Depth	45 mm
Net weight	0.2 kg
Product functions / management, configuration	
Product function / switch-managed	No
Standards, specifications, approvals	
Sianoaros soecilications approvais	
Standard	FM3611: Class 1. Divison 2. Group A. B. C. D / T., Cl. 1. Zone 2.
	FM3611: Class 1, Divison 2, Group A, B, C, D / T, CL.1, Zone 2, GP. IIC, T Ta
Standard	
Standard ● for FM	GP. IIC, T Ta
Standard ● for FM	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4,
Standard • for FM • for hazardous zone	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A)
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A)
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes EN 61000-6-2, EN 61000-6-4
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155 • Railway application in accordance with EN	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes EN 61000-6-2, EN 61000-6-4
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes IS EN 61000-6-2, EN 61000-6-4 No No
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155 • Railway application in accordance with EN	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes EN 61000-6-2, EN 61000-6-4 No
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155 • Railway application in accordance with EN 50124-1	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes IS EN 61000-6-2, EN 61000-6-4 No No Yes
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155 • Railway application in accordance with EN 50124-1 • KC approval	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes IS EN 61000-6-2, EN 61000-6-4 No No Yes
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155 • Railway application in accordance with EN 50124-1 • KC approval Standards, specifications, approvals / ship classifications, ap	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes IS EN 61000-6-2, EN 61000-6-4 No No Yes
Standard • for FM • for hazardous zone • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / miscellaneous Certificate of suitability • Railway application in accordance with EN 50155 • Railway application in accordance with EN 50124-1 • KC approval Standards, specifications, approvals / ship classification association	GP. IIC, T Ta EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X EN 61000-6-4 (Class A) EN 61000-6-2 Yes EN 61000-6-2, EN 61000-6-4 No No Yes

Bureau Veritas (BV)
Det Norske Veritas (DNV)
Germanische Lloyd (GL)
Lloyds Register of Shipping (LRS)
No
Nippon Kaiji Kyokai (NK)
Polski Rejestr Statkow (PRS)
No

Standards, specifications, approvals / product conformity

MTBF 273 y

Further Information / Internet Links

Internet-Link

• to website: Selector SIMATIC NET

SELECTION TOOL

• to website: Industrial communication

• to website: Industry Mall

• to website: Information and Download Center

• to website: Image database

• to website: CAx Download Manager

• to website: Industry Online Support

http://www.siemens.com/snst

http://www.siemens.com/simatic-net

https://mall.industry.siemens.com

http://www.siemens.com/industry/infocenter

http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

Security information

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Thirdparty products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

08/10/2019