



## CC-E range



Warnung! Gefährliche Spannung! Installation nur durch elektro-technische Fachkraft.

Warning! Hazardous voltage! Installation by person with electrotechnical expertise only.

Avertissement! Tension électrique dangereuse! Installation uniquement par des personnes qualifiées en électrotechnique.

¡Advertencia! ¡Tensión peligrosa! La instalación deberá ser realizada únicamente por electricistas especializados.

Avvertenza! Tensione pericolosa! Far installare solo da un elettricista specializzato.

Varning! Farlig spänning! Installation får endast utföras av en elektriker.

Осторожно! Опасное напряжение! Монтаж должен выполняться только специалистом-электриком.

警告! 危险电压! 仅可由电气专业人员安装。

### Technical data:





T<sub>a</sub>: 0 ... +60 °C (+32 ... +140 °F)

IP 20

Pollution degree 2



Appropriate safety measures against electrostatic discharge (ESD) shall be taken during range selection and assembly.

 <p>Ø 3.5 mm / 0.137 in</p>	<p>0.5 Nm 4.4 lb.in</p>
	<p>0.2...4.0 mm<sup>2</sup> 24...12 AWG</p>
	<p>0.2...2.5 mm<sup>2</sup> 24...14 AWG</p>
	<p>0.2...2.5 mm<sup>2</sup> 24...14 AWG</p>

2CDC 282 001 F0015

**1SVR011700R0000, 1SVR011701R2500,  
1SVR011702R2600, 1SVR011703R2700:**

**Additional information relating to cULus approval:**

- A. THIS EQUIPMENT IS SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C, AND D OR NON-HAZARDOUS LOCATIONS ONLY.
- B. WARNING - EXPLOSION HAZARD - SUBSTITUTION OF COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2
- C. WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS.

**Information complémentaire relative à la certification cULus:**

- A. CET ÉQUIPEMENT EST ADAPTÉ À UNE UTILISATION SELON LA CLASS I, DIVISION 2, GROUPES A, B, C, D OU ENVIRONNEMENTS NON DANGEREUX SEULEMENT.
- B. AVERTISSEMENT – RISQUE D'EXPLOSION – LA SUBSTITUTION DE COMPOSANTS PEUT NUIRE À LA CONFORMITÉ CLASSE I, DIVISION 2.
- C. AVERTISSEMENT - RISQUE D'EXPLOSION – NE PAS DÉBRANCHER UN COMPOSANT AVANT D'AVOIR COUPÉ L'ALIMENTATION OU D'ÊTRE EN PRÉSENCE D'UNE ZONE NON DANGEREUSE