SIEMENS

Data sheet

6ES7151-7AA21-0AB0

SIMATIC DP, IM151-7 CPU for ET200S, 128 KB work memory with integrated PROFIBUS DP interface (9-pole D-sub socket) as DP slave, without battery SIMATIC MMC required



General information	
HW functional status	01
Firmware version	V3.3
Engineering with	
Programming package	V5.5 + SP1 or higher or V5.2 + SP1 or higher + HSP 219
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes; against destruction
external protection for power supply lines	2 A min.
(recommendation)	
Mains buffering	
Mains/voltage failure stored energy time	5 ms
Input current	
Inrush current, max.	1.8 A; Typical
l²t	0.09 A ² ·s
from supply voltage 1L+, max.	320 mA; 410 mA with DP master module

Output current	
for backplane bus (5 V DC), max.	700 mA
Power loss	
Power loss, typ.	4.2 W
Manage	
Memory Work memory	
• integrated	128 kbyte
• expandable	No
Size of retentive memory for retentive data	64 kbyte
blocks	
Load memory	
• Plug-in (MMC)	Yes
• Plug-in (MMC), max.	8 Mbyte
 Data management on MMC (after last programming), min. 	10 y
Backup	
• present	Yes; Ensured by SIMATIC Micro Memory Card (maintenance-
	free)
CPU processing times	
for bit operations, typ.	0.06 μs
for word operations, typ.	0.12 μs
for fixed point arithmetic, typ.	0.16 μs
for floating point arithmetic, typ.	0.59 μs
CPU-blocks	
Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks
	can be reduced by the MMC used.
DB	
Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	4004 N. 4. 7000
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC 2 November 2 was a	1 024: Number renge: 0 to 7000
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
OB Description	See S7-300 operation list
Description Size may	64 kbyte
Size, max. Number of free syste ORs.	1; OB 1
Number of free cycle OBs	1; OB 10
Number of time alarm OBs Number of delay clarm OBs	
 Number of delay alarm OBs 	2; OB 20, 21

 Number of cyclic interrupt OBs 	4; OB 32, 33, 34, 35
 Number of process alarm OBs 	1; OB 40
 Number of DPV1 alarm OBs 	3; OB 55, 56, 57
 Number of startup OBs 	1; OB 100
 Number of asynchronous error OBs 	6; OB 80, 82, 83 (for centralized I/O only, not for distributed I/O), 85, 86, 87
 Number of synchronous error OBs 	2; OB 121, 122
Nesting depth	
• per priority class	16
 additional within an error OB 	4

Counters, timers and their retentivity	
S7 counter	
• Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
IEC counter	
• present	Yes
• Type	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
• Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Type	SFB
• Number	Unlimited (limited only by RAM capacity)

		and			

Flag

• Number, max.	256 byte
Retentivity available	Yes; MB 0 to MB 255
 Retentivity preset 	MB 0 to MB 15
 Number of clock memories 	8; 1 memory byte
Data blocks	
Retentivity adjustable	Yes; via non-retain property on DB
 Retentivity preset 	Yes
Local data	
• per priority class, max.	32 kbyte; Max. 2048 bytes per block
Address area	
I/O address area	
• Inputs	2 048 byte
Outputs	2 048 byte
of which distributed	
— Inputs	2 048 byte
— Outputs	2 048 byte
Process image	
• Inputs	2 048 byte
Outputs	2 048 byte
 Inputs, adjustable 	2 048 byte
 Outputs, adjustable 	2 048 byte
Inputs, default	128 byte
 Outputs, default 	128 byte
Digital channels	
• Inputs	16 336
— of which central	496
Outputs	16 336
— of which central	496
Analog channels	
• Inputs	1 021
— of which central	124
Outputs	1 021
— of which central	124
Hardware configuration	
Number of modules per system, max.	63; Centralized
Mounting rail	
 Number of mounting rails that can be used 	1
Length of mounting rail, max.	Station width: ≤ 1 m or < 2 m
Time of day	
Clock	

Hardware clock (real-time)	Yes		
	Yes		
• retentive and synchronizable	6 wk; At 40 °C ambient temperature, typically		
Backup time			
Deviation per day, max.	10 s; Typ.: 2 s		
Behavior of the clock following POWER-ON	Clock continues running after POWER OFF		
 Behavior of the clock following expiry of backup period 	Clock continues to run with the time at which the power failure occurred		
Operating hours counter			
• Number	1		
Number/Number range	0		
Range of values	0 to 2^31 hours (when using SFC 101)		
Granularity	1 h		
• retentive	Yes; Must be restarted at each restart		
Clock synchronization			
• supported	Yes		
• to MPI, master	Yes		
• to MPI, slave	Yes		
• to DP, master	Yes; With DP slave only slave clock		
• to DP, slave	Yes		
• in AS, master	No		
• in AS, slave	No		
Interfaces			
Interfaces Interfaces/bus type	1 x MPI/PROFIBUS DP		
	1 x MPI/PROFIBUS DP		
Interfaces/bus type			
Interfaces/bus type Number of industrial Ethernet interfaces	0		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces	0		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces	0		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface	0 0 0		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated	0 0 0 Integrated RS 485 interface		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max.	0 0 0 Integrated RS 485 interface RS 485		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated	0 0 0 Integrated RS 485 interface RS 485 Yes 80 mA		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max.	0 0 0 Integrated RS 485 interface RS 485 Yes		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols	0 0 0 Integrated RS 485 interface RS 485 Yes 80 mA		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols • MPI	0 0 0 Integrated RS 485 interface RS 485 Yes 80 mA		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols • MPI • PROFIBUS DP master	0 0 Integrated RS 485 interface RS 485 Yes 80 mA Yes No		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave	0 0 Integrated RS 485 interface RS 485 Yes 80 mA Yes No Yes; active / passive		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave • Point-to-point connection	0 0 Integrated RS 485 interface RS 485 Yes 80 mA Yes No Yes; active / passive		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave • Point-to-point connection MPI	0 0 Integrated RS 485 interface RS 485 Yes 80 mA Yes No Yes; active / passive No		
Interfaces/bus type Number of industrial Ethernet interfaces Number of PROFINET interfaces Number of wireless interfaces 1. Interface Interface type Physics Isolated Power supply to interface (15 to 30 V DC), max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave • Point-to-point connection MPI • Transmission rate, max.	0 0 Integrated RS 485 interface RS 485 Yes 80 mA Yes No Yes; active / passive No		

 Global data communication 	Yes
— S7 basic communication	Yes
— S7 communication	Yes; Only server, configured on one side
 S7 communication, as client 	No
 S7 communication, as server 	Yes
PROFIBUS DP slave	
• GSD file	The latest GSD file is available on the Internet
	(http://www.siemens.com/profibus-gsd)
Transmission rate, max.	12 Mbit/s
automatic baud rate search	Yes; only with passive interface
Address area, max.	32
User data per address area, max.	32 byte; Up to max. size of the transfer memory
Services	
— PG/OP communication	Yes
— Routing	Yes; Only with active, integrated DP slave interface and inserted DP master module in DP master mode
 Global data communication 	No
 S7 basic communication 	No
— S7 communication	Yes; Only server, configured on one side
 S7 communication, as client 	No
 S7 communication, as server 	Yes
 — Direct data exchange (slave-to-slave communication) 	Yes
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
Interface type	External interface via master module 6ES7138-4HA00-0AB0
Physics	RS 485
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	No
Protocols	
• MPI	No
PROFIBUS DP master	Yes
PROFIBUS DP slave	No
PROFIBUS DP master	
• Transmission rate, max.	12 Mbit/s
Number of DP slaves, max.	32; Per station
Services	
— PG/OP communication	Yes
— Routing	Yes

 Global data communication 	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes; Only server, configured on one side
 S7 communication, as client 	No
 S7 communication, as server 	Yes
— Equidistance	Yes
 Isochronous mode 	No
— SYNC/FREEZE	Yes
 Activation/deactivation of DP slaves 	Yes
 Number of DP slaves that can be 	8
simultaneously activated/deactivated, max.	
 — Direct data exchange (slave-to-slave communication) 	Yes
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	
— Inputs, max.	244 byte
— Outputs, max.	244 byte
Jeochronoue modo	
Isochronous mode Isochronous operation (application synchronized up	No
Isochronous mode Isochronous operation (application synchronized up to terminal)	No
Isochronous operation (application synchronized up to terminal)	No
Isochronous operation (application synchronized up to terminal) Communication functions	
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication	Yes
Isochronous operation (application synchronized up to terminal) Communication functions	
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication	Yes
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported	Yes Yes; With DP master module
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max.	Yes Yes; With DP master module Yes
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max.	Yes Yes; With DP master module Yes 8
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max.	Yes Yes; With DP master module Yes 8 8
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max.	Yes Yes; With DP master module Yes 8 8 8 8
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max. • Size of GD packets, max.	Yes Yes; With DP master module Yes 8 8 8
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max.	Yes; With DP master module Yes 8 8 8 8 8 8 22 byte
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max. • Size of GD packets, max. • Size of GD packet (of which consistent), max. S7 basic communication	Yes; With DP master module Yes 8 8 8 8 8 8 22 byte
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max. • Size of GD packets, max. • Size of GD packet (of which consistent), max. S7 basic communication • supported	Yes Yes; With DP master module Yes 8 8 8 8 22 byte 22 byte
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max. • Size of GD packets, max. • Size of GD packet (of which consistent), max. S7 basic communication	Yes Yes; With DP master module Yes 8 8 8 8 8 22 byte 22 byte
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max. • Size of GD packets, max. • Size of GD packet (of which consistent), max. S7 basic communication • supported • User data per job, max.	Yes Yes; With DP master module Yes 8 8 8 8 22 byte 22 byte Yes 76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with
Isochronous operation (application synchronized up to terminal) Communication functions PG/OP communication Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max. • Size of GD packets, max. • Size of GD packet (of which consistent), max. S7 basic communication • supported • User data per job, max. • User data per job (of which consistent), max.	Yes Yes; With DP master module Yes 8 8 8 8 22 byte 22 byte Yes 76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with

	V
• as server	Yes
• as client	No
User data per job, max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
• User data per job (of which consistent), max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
Number of connections	
• overall	12
 usable for PG communication 	11
 reserved for PG communication 	1
 adjustable for PG communication, min. 	1
 adjustable for PG communication, max. 	11
 usable for OP communication 	11
 reserved for OP communication 	1
 adjustable for OP communication, min. 	1
 adjustable for OP communication, max. 	11
usable for S7 basic communication	10
 reserved for S7 basic communication 	0
 adjustable for S7 basic communication, 	0
min.	
 adjustable for S7 basic communication, 	10
max.	
max. ● usable for routing	4; As slave only with active interface, with IM 151-7 CPU as DP master
usable for routing	
usable for routing S7 message functions	master 12; Depending on the configured connections for PG/OP and S7
usable for routing S7 message functions Number of login stations for message functions, max.	master 12; Depending on the configured connections for PG/OP and S7 basic communication
usable for routing S7 message functions Number of login stations for message functions, max.	master 12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D,
usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages	master 12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ
usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block	master 12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ
• usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block Single step	12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ 300
• usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block Single step Number of breakpoints	12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ 300 Yes; Up to 2 simultaneously
• usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block Single step	master 12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ 300 Yes; Up to 2 simultaneously Yes 4
• usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block Single step Number of breakpoints	12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ 300 Yes; Up to 2 simultaneously Yes 4
• usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block Single step Number of breakpoints Status/control	master 12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ 300 Yes; Up to 2 simultaneously Yes 4
• usable for routing S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block Single step Number of breakpoints Status/control • Status/control variable	12; Depending on the configured connections for PG/OP and S7 basic communication Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ 300 Yes; Up to 2 simultaneously Yes 4

Forcing

Forcing

— of which control variables, max.

14

Yes

• Forcing, variables	Inputs, outputs
Number of variables, max.	10
Diagnostic buffer	
• present	Yes
 Number of entries, max. 	500
— adjustable	No
of which powerfail-proof	100; Only the last 100 entries are retained
 Number of entries readable in RUN, max. 	499
— adjustable	Yes; From 10 to 499
— preset	10
Service data	
• can be read out	Yes
Interrupts/diagnostics/status information	
Alarms	Yes
Diagnostics function	Yes
Diagnostics indication LED	
• Group error SF (red)	Yes
 Monitoring 24 V voltage supply ON (green) 	Yes
Potential separation	
between PROFIBUS DP and all other circuit	Yes
components	
Permissible potential difference	
between different circuits	75 V DC/60 V AC
Isolation	
Isolation tested with	500 V DC
Degree and class of protection	
IP degree of protection	IP20
Configuration Configuration rules	max. 63 peripheral modules per station; station width < 1 m or < 2
Comiguration rules	m; max. 10 A per load group (power module); master interface
	module on right next to IM 151-7 CPU (X2 interface)
Configuration software	
• STEP 7 Lite	No
Programming	
Command set	see instruction list
Nesting levels	8
System functions (SFC)	see instruction list
 System function blocks (SFB) 	see instruction list
Programming language	
— LAD	Yes

— FBD	Yes
— STL	Yes
— SCL	Yes; Optional
— CFC	Yes; Optional
— GRAPH	Yes; Optional
— HiGraph®	Yes; Optional
Know-how protection	
User program protection/password protection	Yes
 Block encryption 	Yes; With S7 block Privacy
Cycle time monitoring	
• lower limit	1 ms
• upper limit	6 000 ms
• adjustable	Yes
• preset	150 ms
Dimensions	
Width	60 mm; DP master module: 35 mm
Height	119.5 mm
Depth	75 mm
Weights	
Weight, approx.	200 g; DP master module: Approx. 100 g
last modified:	08/16/2019