

Product description

Test access port with two network ports and two diagnostic ports for discharging telegrams from the network ports (both transmission directions)  
SCALANCE TAP104 Text access port to telegram cable, 2 x RJ45 ports, 10/100MBit/s, LED diagnostics, 24 V DC Supply voltage, Manual



Product type designation	SCALANCE TAP104
Transmission rate	
Transfer rate	10 Mbit/s, 100 Mbit/s
Interfaces / for communication / integrated	
Number of electrical connections	
• for network components or terminal equipment	2; RJ45 with securing collar
Interfaces / others	
Number of electrical connections	
• for power supply	1
Type of electrical connection	
• for power supply	3-pole terminal block
Supply voltage, current consumption, power loss	
Type of voltage / of the supply voltage	DC
Supply voltage	
• external	24 V

• external / minimum	18 V
• external / maximum	31.2 V
Product component / fusing at power supply input	Yes
Fuse protection type / at input for supply voltage	0.5 A / 60 V
Consumed current / maximum	0.06 A
Power loss [W]	
• at DC / at 24 V	1.44 W

#### Permitted ambient conditions

Ambient temperature	
• during operation	-40 ... +70 °C
• during storage	-40 ... +85 °C
• during transport	-40 ... +85 °C
Relative humidity	
• at 25 °C / without condensation / during operation / maximum	95 %
Protection class IP	IP20

#### Design, dimensions and weight

Design	compact
Width	35 mm
Height	152 mm
Depth	135 mm
Net weight	0.24 kg
Mounting type	Installation with a stand and in 19" rack using accessory components
• 35 mm DIN rail mounting	Yes
• wall mounting	Yes
• S7-300 rail mounting	Yes
• S7-1500 rail mounting	Yes

#### Product functions / Redundancy

Product function	
• Parallel Redundancy Protocol (PRP)/operation in the PRP-network	Yes
• Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA)	No

#### Standards, specifications, approvals

Standard	
• for FM	FM3611: Class 1, Division 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
• for hazardous zone	EN 60079-0:2009, EN60079-15:2010, II 3 G Ex nA IIC T4 Gc, KEMA 07ATEX0145 X
• for safety / from CSA and UL	UL 60950-1, CSA C22.2 No. 60950-1
• for emitted interference	EN 61000-6-4 (Class B)

- for interference immunity

EN 61000-6-2

## Standards, specifications, approvals / CE

Certificate of suitability / CE marking

Yes

## Standards, specifications, approvals / miscellaneous

Certificate of suitability

EN 61000-6-2, EN 61000-6-4

- C-Tick

No

- KC approval

Yes

## Further Information / Internet Links

Internet-Link

- to website: Selector SIMATIC NET SELECTION TOOL
- to website: Industrial communication
- to website: Industry Mall
- to website: Information and Download Center
- to website: Image database
- to website: CAx Download Manager
- to website: Industry Online Support

<http://www.siemens.com/snst>

<http://www.siemens.com/simatic-net>

<https://mall.industry.siemens.com>

<http://www.siemens.com/industry/infocenter>

<http://automation.siemens.com/bilddb>

<http://www.siemens.com/cax>

<https://support.industry.siemens.com>

## Security information

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action (e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit <http://www.siemens.com/industrialsecurity>. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit <http://support.automation.siemens.com>. (V3.4)

last modified:

05/15/2019